

## Consumer Confidence Report # 21

## Rockwell's Water Quality 2019

CONTAMINANT	MCLG	MCL	DETECTED LEVEL	DATE SAMPLED	RANGE OF DETECTION	VIOLATION	SOURCE
Copper	1.3	AL=1.3	0.31	9/18/2019	0.1429 (0.0292 - 0.182)	No	Corrosion of household plumbing systems, erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	0	AL=15	0.02826	9/18/2019	1.57 (1 -3)	No	Corrosion of household plumbing systems, erosion of natural deposits
<b>DISTRIBUTION SYSTEM</b>							
Chlorine	4	4	1.8 mg/L	12/31/2019	high 2.1 low 1.4	No	water additive used to control microbes
Barium (ppm)	2	-2	0.183	5/21/2012	NA	No	Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits
Sodium (ppm)	NA	NA	19.9	6/13/2018	NA	No	Erosion of natural deposits. Added to water during treatment process.

Consumer Confidence Report # 21  
 Rockwell's Water Quality 2019

Alpha emitters (pCi/L)	0	15	4.4	4/13/2015	N/A	No	Erosion of natural deposits
Combined Radium	N/A	5	1.2	4/13/2015	<0 5-1.8	No	Erosion of natural deposits
Fluoride (ppm)	4	4	2.52	6/13/2018	N/A	No	Water Additive. Erosion of natural deposits, discharge from fertilizer and aluminum factories